



1101 McKinley Street
Anoka, MN 55303
Phone (763) 786-6682
Fax (763) 786-2167
www.polycam.com



Part Name: Gas Transition with Female NPT
Part Number: 812-xxxx

Threaded Transitions

The POLY-CAM Threaded Transition is a multi-level mechanical transition fitting. The polyethylene or pipe-quality copolymer material are hydraulically compressed into the transition fitting.

Design

Relaxation of the pipe creates a seal to prevent leakage. Under pressure, the internal pressure within the pipe increases the sealing surface area on the barb. Under zero internal pressure, the compression and tensional strain created by the compression of the multi-level barbs are greater than the stress created by relaxation and/or thermal expansion and contraction. As the internal pressure increases, the connection between the pipe material and transition fitting increases. A stainless steel insert is installed to reinforce the connection. This design meets ASTM D2513, Category 1. The fitting is **not** designed for above ground applications.

- Sizes range from .5 to 8" NPT.
- All National Pipe Threads are made to ANSI/ASME B1.20.1 - 2013.
- Available in MDPE or HDPE.

System Performance

The transition fitting is designed to handle the pressure rating of the HDPE pipe with a 2:1 safety factor at 73.40 degrees Fahrenheit with a minimum 50-year design life.

Quality Assurance

The transition fitting shall be manufactured by Poly-Cam, Inc. Poly-Cam, Inc. shall provide quality assurance with regards to proper installation, compatibility, performance, and acceptance. The transition joint meets or exceeds the requirements of:

- ASTM D2513, Category 1
- ARRA requirements
- ASTM F2897: Tracking and Traceability Encoding System
- ASTM D3261

Installation

HDPE pipe end: Install transition fitting to comply with the pipe manufacturer's recommended procedures. All field welds shall be completed per Plastic Pipe Institute's welding procedure for butt fusion.

Threaded Fitting: When installing the transition fitting:

- Always use pipe joint sealant or Teflon tape.
- Always use strap wrenches.
- **Do not use a pipe wrench.**
- **Always use 2 wrenches when connecting.**
- **Over tightening may cause ovality or damage.**
- **Always pressure test for leaks before backfilling.**
- Backfill and compact carefully around transition and service line to prevent ground shifts which could damage the valve and/or transition fitting.

Material

Threaded Fitting:

- Manufactured of Carbon Steel (A53 or A106 grade), Type 304 or Type 316 Stainless Steel (ASTM A249 or ASTM A269), C954 grade Aluminum Bronze (Lead Free material this complies with California AB1953, SB1334 and SB1935), or ERW pipe (ASTM SA-312).
- For carbon steel, the **epoxy coating** (IF 194T Red Iron Oxide) is fusion bonded to the metal. Meets NSF 61, FDA 175.300, AWWA C116-01, C213-01, UL 262 and FM 1120/1130

High-Density Polyethylene (HDPE) or Medium-Density Polyethylene Pipe (MDPE):

- Incorporated with the fitting is:
 - MDPE - PE2406/2708 (PE234373E and PE234375E)
 - HDPE - PE3408/3608 (cell class 345464C)/PE4710 (PE445574C)
- All pipe meets ASTM D3035 and ASTM D2513.

Stainless Steel insert - The insert is manufactured out 304 or 316 stainless steel tubing (ASTM A249 or ASTM A269).

Warranty

The warranty period is one year after the date of substantial completion of installation.

Series 812 Gas Transition with Female NPT

SDR7

Nominal Size (In.)	Coupling O.D. A	Pressed SDR7 PE Pipe I.D. B	Exposed SDR7 PE Pipe I.D. C	Exposed PE Pipe O.D. D	Coupling Length E	Exposed PE Pipe Length F	Overall Length G	Thread Length H
0.75	1.245	~0.70	0.73	1.050	1.6	23	25	0.8
1	1.500	~0.72	0.92	1.315	2	23	25	0.91
1.25	1.900	~0.90	1.16	1.660	2.6	23	25	0.95
1.5	2.350	~1.10	1.33	1.900	3	23	25	0.9
2	2.540	~1.44	1.66	2.375	4	22.5	25	1
3	4.144	~2.08	2.44	3.500	5.6	22	26	1.6
4	5.160	~2.79	3.14	4.500	5.875	22	26	1.875
5	6.260	~3.4	3.88	5.563	6.75	22	26	1.75
6	7.390	~4.2	4.62	6.625	6.875	22	26	1.875
8	9.650	~5.5	6.01	8.625	9.5	21.5	26.5	2.5

